

POOL

Public Swimming Pool Daily Record Sheet



Month / Year	Name of Pool:	Location - City
--------------	---------------	-----------------

Operator's Initials	DATE	Daily Pre-Opening Tests					Total Alkalinity (1x / week)	Calcium Hardness (1x / wk)	Cyanuric Acid (1x / week)	TDS (Monthly)	Free Cl / Br Readings (1 or 4 hrs)						Number of Bathers - Total	Backwashed - Clean Filters	Recirculation Rate - GPM	Comments -
		Clarity	Pool Temp	Free Chlorine/Bromine	Combined Cl	pH					Insert the Time the Test is Done (below)									
	1																			
	2																			
	3																			
	4																			
	5																			
	6																			
	7																			
	8																			
	9																			
	10																			
	11																			
	12																			
	13																			
	14																			
	15																			
	16																			
	17																			
	18																			
	19																			
	20																			
	21																			
	22																			
	23																			
	24																			
	25																			
	26																			
	27																			
	28																			
	29																			
	30																			
	31																			

Comments: _____

Swimming Pool Water Quality Parameters			
	Min.	Ideal	Max.
Free Chlorine	0.8 ppm	1.5-3.0 ppm	5.0 ppm
Combined Chlorine	0	0	0.5 ppm
Bromine	3.0 ppm	3.0-5.0 ppm	8.0 ppm
pH	7.2	7.3-7.5	7.6
Total Alkalinity	70 ppm	80-120 ppm	180 ppm
Calcium Hardness	175 ppm	250-350 ppm	-
Cyanuric Acid	0	0	150 ppm

