

SPA

Public Spa Pool Daily Record Sheet



Month / Year	Name of Pool:	Location - City
--------------	---------------	-----------------

Operator's Initials	DATE	Pre-opening Tests					Total Alkalinity (2x / week)	Calcium Hardness (1x / wk)	Cyanuric Acid (1x / week)	Free Cl/ Br readings Every 2 hours Insert time				pH levels every 2 hours Insert time				Recirculation Rate - GPM	Comments - -Water changes -Chemicals added -Mechanical Breakdowns -Emergencies -Back Wash -Clean Filters -Water added(inch)
		Clarity	SPA Temp (<104°F.)	Free Chlorine / Bromine	Combined Cl	pH													
	1																		
	2																		
	3																		
	4																		
	5																		
	6																		
	7																		
	8																		
	9																		
	10																		
	11																		
	12																		
	13																		
	14																		
	15																		
	16																		
	17																		
	18																		
	19																		
	20																		
	21																		
	22																		
	23																		
	24																		
	25																		
	26																		
	27																		
	28																		
	29																		
	30																		
	31																		

Comments: _____

Public Spa Pool - Water Quality Parameters			
	Min.	Ideal	Max.
Free Chlorine	1.5 ppm	3.0 - 5.0 ppm	5.0 ppm
Combined Chlorine	0	0	0.5 ppm
Bromine	3.0 ppm	3.0-5.0 ppm	8.0 ppm
pH	7.2	7.3-7.5	7.6
Total Alkalinity	70 ppm	80-120 ppm	180 ppm
Calcium Hardness	175 ppm	250-350 ppm	-
Cyanuric Acid	0	0	150 ppm

SPA

Public Spa Pool Safety Checklist



Month / Year		License Number
Name of Facility		
Street Address		
City, State Zip		
Name of Operator		Phone

Monthly Safety Self-Inspection

Item Checked

Maintenance Comments

Spa & Enclosure

- Fences – Openings < 4", Good Repair
- Doors & Gates – Self-Closes, Completely Latches, Good Condition
- Window / Sliding Glass Door – Open < 4"
- Deck Equipment – Good Condition, Fasteners and Fittings not corroded
Stairs – Handrail tight
- Depth Marking – Easily Readable
- Deck – Clean, Disinfected, Good Repair, No Puddles, No Carpet/Matting/Wood
- Spa Basin – In Good Repair
- Skimmers / Gutters / Tile Line – Clean, Good Repair
- Lighting – Maintained, Adequate
- Safety Equipment – Provided, Good Repair
First Aid Kit Stocked, Phone Working
- Test Kit – Clean, Stocked w/ Fresh Reagents, Stored in Cool, Dry Location
- Spa Temperature - <104°F. (Ideal 102°F. or less)
- Water Changed – at least monthly, best changed when ("# of bathers" = Volume (gal.) / 3)

Recirculation Equipment

- Pumps / Filter / Disinfectant Feeders
Maintained, Good Repair
- Gauges – Working, Accurate
Readings within Parameters
- Piping – Good Repair, Marked, No Leaks
